



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/09/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	rsco 6a	c/d tripped on olr	reset done	08:15:00	08:25:00	
2	OHP	CO 10A	TRIPPED ON OLR/	RESET DONE	06:40:00 09:00:00	06:50:00 09:10:00	
3	OHP	CO 29	TRIPPED ON OLR	RESET DONE	09:10:00	09:20:00	
4	OHP	SB-1 VF=14 side	Bunker High limit changed	Reduced from 67 % to 50% on operation request	13:00:00	13:00:00	
5	OHP	LC-7 lighting timer	Output bit (Q 65.1) configured at LC-7 IO rack, wiring done .	Manual ON Selector switch provided on its panel for Manual Switching	13:00:00	13:00:00	
6	CHP	R1 ON CC 39	LT NOT TAKING PLACE/PCRD CABLE TENSION ACTED	LIMIT ADJUSTED	11:35:00	11:45:00	
7	CHP	CC131	TRIPPED ON OLR	RESET DONE	13:25:00	13:30:00	