



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/07/2026

Shift: C

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-13 (c) drive	mpcb trip	made on than ok	03:10:00	03:20:00	
2	OHP	TBS ON CO-5A	LT NOT MOVING	PCRD TENSION ACTED ..NO CABLE IN DRUM ..LENGTH SHORT . RELEASED	23:20:00	23:40:00	
3	OHP	WBR ON CO-25	LT NOT MOVING	PCRD OT ACTED ... RELEASED	05:00:00 23:12:00	06:00:00 23:30:00	PCRD CHAIN PROBLEM .. MECH ON JOB
4	OHP	VF-10A	MPCB TRIPPED	RESET DONE	00:20:00	00:30:00	
5	OHP	CO-26	TRIPPED ON OLR	RESET DONE	03:30:00	03:40:00	
6	OHP	CC-33M	TRIPPED ON OLR	RESET DONE	04:40:00	04:50:00	
7	CHP	CC-213 SCR-9	SLEW LIMIT ACTED	RELEASED AND TESTED	23:25:00	23:40:00	
8	CHP	CC-107	TRIPPED ON OLR	RESET DONE	00:30:00 03:40:00	00:35:00 03:45:00	
9	WT	OT-4	NOT ZERO POSITION	SENSOR ADJUSTMENT DONE THAN OK	22:55:00	23:00:00	
10	WT	CP-1	NOT MOVING	CHECKED AND RESET IN SCADA	02:25:00	02:35:00	
11	WT	OT -1	NOT ROTATING	EM ACTED ... RELEASED	03:00:00	03:05:00	