



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 04/07/2026

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment                  | Problem                     | Action                                 | From     | To       | Remarks |
|-------|------|----------------------------|-----------------------------|----------------------------------------|----------|----------|---------|
| 1     | OHP  | WBR ON<br>CO 29<br>LUFF    | OLR ACTED                   | RESET                                  | 04:10:00 | 04:25:00 |         |
| 2     | CHP  | CC 26A<br>MCCB<br>TRIPPING | MCCB SETTING DISTURBED      | READJUSTED                             | 23:00:00 | 23:30:00 |         |
| 3     | WT   | OP6                        | BREAKER TRIPPING FREQUENTLY | C TYPE ISOLATOR KEPT OFF AT COLL NO 46 | 23:30:00 | 00:15:00 |         |