



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/05/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO 29 LT	PCRD GEAR BOX PROBLEM	INFORMED TO MECH	18:30:00	19:00:00	
2	OHP	WBR ON CO 26 SLEW	DRIVE TRIPPED	RESET	21:20:00	21:30:00	
3	CHP	CC 48 BRS	SENSOR CLEANED	RESET	16:25:00	16:35:00	
4	CHP	SCR 3 ON CC 37 B/W	OUTPUT FUSE BLOWN	REPLACED	16:40:00	16:55:00	
5	CHP	CC 40	OVERLOAD PROBLEM	REPLACED	19:30:00	20:30:00	
6	CHP	R1 ON CC 36 B/C	OLR ACTED	RESET	20:50:00	21:10:00	
7	CHP	CC 51	OLR ACTED	RESET	15:20:00	18:30:00	3 TIMES
8	CHP	CC 26 A	OLR ACTED	RESET	15:00:00	21:00:00	3 TIMES