



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/09/2026

Shift: B

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment         | Problem                           | Action   | From     | To       | Remarks                       |
|-------|------|-------------------|-----------------------------------|----------|----------|----------|-------------------------------|
| 1     | OHP  | CO 25             | OLR acted                         | Reset    | 20:50:00 | 21:00:00 |                               |
| 2     | CHP  | CC 131            | OLR acted                         | Reset    | 15:30:00 | 21:00:00 | 5 Times                       |
| 3     | CHP  | SCR 7 on<br>CC 40 | Luff MPD trip                     | Reset    | 20:10:00 | 20:25:00 |                               |
| 4     | CHP  | CC 22             | ZSS Module to Probe cable Problem | Bypassed | 20:20:00 | 20:40:00 | Cable Changing under progress |
| 5     | CHP  | CC 28 to<br>CC 33 | Glass fuse blown                  | Replaced | 21:15:00 | 21:30:00 |                               |