



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/09/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 58	OLR acted	Reest	02:45:00	02:55:00	
2	CHP	CC 58	OLR acted	Reset	02:10:00	02:30:00	
3	CHP	CC 131	OLR acted	Reset	04:40:00	04:45:00	
4	CHP	CC 22	OLR acted	Reset	04:00:00	04:10:00	