



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 10/09/2026

Incharge(s): Saurabh Kumar Yadav, M Kailash

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CR 1	mpr tripped due to ol	reset	02:10:00 23:25:00	02:25:00 23:40:00	
2	OHP	co 48	olr acted	reset	00:25:00	00:40:00	
3	CHP	cc 55 and 114	no power , I/C 2 tripped in LBDS 4, breaker spring is in discharged condition	in lbd4 master relay is in tripped condition not getting set ,it reset after 10 minutes, spring charged, finally PNLno 36 made on in LBDS4	00:20:00	01:05:00	In LC19 I/C 2 made off and B/C made on***, to be normalized after stream stopped or in A shift***
4	CHP	CC 40 scr7	luff not working, pump is in off condition	pump made it on cmd	02:55:00	03:05:00	
5	CHP	CC 32	scr 5 B/c stoppped in ZSS, coal piece stucked in cage	cage cleaned	03:17:00	03:30:00	
6	CHP	CC 131	mpd acted	reset	05:25:00	05:30:00	
7	CHP	CC 28	flap gate motor mpcb tripped	amde it on	04:00:00	04:10:00	