



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/05/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBSD on co 21	LT ,b/c and slew not working,olr acted and heavily jamming,,, communication problem	olr reset,mcb phase wire tightened for RTU supply	00:00:00	00:25:00	
2	CHP	CC 51	mpd acted	reset	23:30:00	23:35:00	
3	IOSA	ALL CONV EYOR RED	PLC COMMUNICATION PROBLEM	POWER ECYCLE IN LC AND OMS	23:33:00	23:59:00	