# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL GENERAL SHIFT REPORT

Date: 06/11/2026

Area: WT

| Equipment | Job |
|---|---|
| CP 2 | Panel and Motor side ppm done,D3 and 4 cascade contactor replaced |
| CP 4 | Trolley line inspection done ,found cable damaged @col no 58, isolated |
| CC 7,8 and 9 | Tunnel , CC 2 ,3 and AF level lighting inspection done |