



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/05/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 29	olr atced	reset	23:15:00	23:20:00	
2	OHP	co 32	olr acted	reset	01:05:00	01:15:00	
3	OHP	BRC on co 30	no power,y phase lug got cu in T/F HT side,isolator made of,earth made on	new lugged done megger done with earth made off,machine than charged and all checked found ok,given clearance	22:00:00	23:08:00	
4	OHP	wobr on co 6A	b/w and slew not working,oil level low	informed operation	00:45:00	01:00:00	
5	OHP	WOBR on co 29	b/w,luff and slew not working olr acted	reset	05:10:00	05:30:00	
6	OHP	RSCO 10A(c)	OLR acted	reset	23:05:00	23:10:00	
7	CHP	CC 51	mpd acted	reset	23:30:00	23:35:00	
8	IOSA	L and T wobr	cjd acted multiple times witout material	probe cleaned	03:40:00	04:20:00	