



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/05/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO 7A LT	DRIVE TRIPPED	RESET	10:20:00	10:30:00	
2	OHP	TT3	OLD JOINT GOT RUBBED	PROPERLY INSULATED	12:50:00	13:10:00	
3	CHP	SCR 10 ON CC 105	AFTER DNW CLEARANCE	MACHINE CHARGED	06:00:00	07:45:00	
4	CHP	CC 28	OLR ACTED	RESET	08:30:00	08:40:00	
5	CHP	CC 131	OLR ACTED	RESET	11:55:00	12:00:00	
6	CHP	CC 130 TIS	OLR ACTED	RESET	09:10:00	09:15:00	
7	CHP	CC 51A	OLR ACTED	RESET	09:25:00	09:30:00	