



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 12/05/2026

Area: WT

Equipment	Job
OT 3	Panel and Motor side blowing and termination checking done
OP 10	AC cables identified ,connected and tested,OK
OP 4	checked and Anti collision sensor kept in circuit
OP 5	Anti collision cable laid ,connected and tested
OP 6	Panel and motor side ppm done ,2 nos pads replaced