



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/05/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	olr acted	reset	09:25:00	09:35:00	
2	OHP	wobr on co 29	pending from c shift,motor value checked from EMC found faulty,	motor replaced,alignment done trial run done given clearance	06:00:00	09:00:00	
3	CHP	CC 130 TIS	mpcb tripped	made it on	06:20:00	06:25:00	
4	CHP	CC 54	olr acted	reset	12:05:00	12:08:00	
5	CHP	SCR7 cc 39	bc not running,mpd tripped	reset	10:10:00	10:20:00	