



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/07/2026

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO 5A	LT NOT TAKING PLACE/PCRD TENSION ACTED	TENSION RELEASED	14:45:00	15:05:00	
2	OHP	WOBR ON CO 29	LUFFING NOT TAKING PLACE/PUMP OLR ACTED	RESET DONE	14:45:00	15:00:00	
3	OHP	TBS ON CO 20	LT NOT TAKING PLACE/PCRD CABLE TENSION ACTED DUE CABLE WINDING ENTANGLED	CABLE WINDING JOB IS GOING ON ALONG WITH MECH.	20:50:00	21:50:00	
4	OHP	CO 29	TRIPPED ON OLR	RESET DONE	20:45:00	20:50:00	
5	CHP	CC 31	MPD TRIPPED ON OLR	RESET DONE	18:30:00	18:40:00	
6	CHP	CC 125	TRIPPED ON OLR.	RESET DONE	19:35:00	19:40:00	
7	CHP	CC 203	TRIPPED ON OLR	RESET DONE	14:40:00	14:50:00	
8	WT	OP 9	F/R NOT TAKING PLCE/ OT 5 TOP CLAMP LS 7 LIMIT ACTING	BYPASSED IN SYSTEM	20:40:00	20:50:00	