



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 31/07/2026

Incharge(s): Nagendra Midde

Shift: B

| Sl No | Area | Equipment        | Problem                | Action    | From     | To       | Remarks |
|-------|------|------------------|------------------------|-----------|----------|----------|---------|
| 1     | OHP  | CO 29            | OLR acted              | Reset     | 15:35:00 | 15:45:00 |         |
| 2     | OHP  | CO 34            | C/S Fuse loose         | Tightened | 16:10:00 | 16:20:00 |         |
| 3     | OHP  | WBR on CO 29 B/W | OLR acted              | Reset     | 20:45:00 | 20:55:00 |         |
| 4     | CHP  | CC 52            | Feeding conv OLR acted | Reset     | 14:30:00 | 14:35:00 |         |
| 5     | CHP  | CC 51            | Feeding conv OLR acted | Reset     | 14:50:00 | 14:55:00 |         |