RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 04/11/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 64	MPCb trip	Reset	22:40:00	22:50:00	
2	OHP	co-26	OLR ACTED (3TIMES)	RESET DONE	03:45:00 05:00:00 22:35:00	03:55:00 05:05:00 22:40:00	
3	OHP	CO-25	OLR ACTED (2TIMES)	RESET DONE	00:05:00 01:55:00	00:10:00 02:00:00	
4	OHP	BRC ON CO-28	REPORTED LT NOT TAKING PLACE FOUND DRIVE TRIP	M-4 MOTOR DIS-CONNECTED AND DRIVE REST DONE	22:40:00	22:55:00	
5	OHP	CC-36, R-1	REPORTED B/C NOT RUNNING FOUND CHUTE JAMMING	INFORMED TO OPERATION	02:30:00	02:45:00	
6	CHP	CC-104, SCR-9	B/W NOT RUNNING FOUND OIL COOLER PUMP MPR TRIP	REST DONE	00:00:00	00:15:00	
7	CHP	CC 54	OLR acted	Reset	04:05:00	05:05:00	2 times
8	CHP	CC 131	OLR acted	Reset	04:30:00	04:35:00	
9	CHP	SCR 9 on CC 104	B/W OIL cooler Pump Trip	Reset	00:00:00	00:15:00	
10	CHP	R1 on CC 36 B/C	Chute Jamming	Informed to oprn	02:30:00	02:45:00	
11	CHP	CC 43	oLR acted	Reset	04:50:00	05:00:00	
12	WT	OT4	D1 trip	Reset	22:40:00	22:45:00	
13	IOSA	OC-37A	REPORTED MECHANICAL BRS NOT WORKING FOUND MCB TRIP	MCB MADE ON THAN OK	03:45:00	04:00:00	