



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/05/2026

Incharge(s): Nagendra Midde

Shift: B

| Sl No | Area | Equipment           | Problem         | Action           | From                 | To                   | Remarks |
|-------|------|---------------------|-----------------|------------------|----------------------|----------------------|---------|
| 1     | OHP  | CO 26               | OLR ACTED       | RESET            | 16:45:00<br>18:20:00 | 16:55:00<br>18:25:00 |         |
| 2     | OHP  | WBR ON<br>CO 6A B/W | OIL LEVEL LOW   | INFORMED TO MECH | 15:15:00             | 15:25:00             |         |
| 3     | OHP  | CO 29               | OLR ACTED       | RESET            | 16:00:00             | 21:15:00             | 3 TIMES |
| 4     | OHP  | CO 13 CD            | MPCB TRIPPED    | RESET            | 17:30:00             | 17:40:00             |         |
| 5     | CHP  | CC 107              | OLR ACTED       | RESET            | 17:15:00             | 17:20:00             |         |
| 6     | WT   | OP8 NOT<br>MOVING   | DRIVE 2 PROBLEM | BYPASSED         | 21:45:00             | 21:55:00             |         |