



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 01/07/2026

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment                | Problem                | Action           | From     | To       | Remarks |
|-------|------|--------------------------|------------------------|------------------|----------|----------|---------|
| 1     | OHP  | BRC ON<br>CO 28 B/W<br>2 | CHAIN SLIP             | INFORMED TO MECH | 22:40:00 | 22:55:00 |         |
| 2     | OHP  | CO 26                    | OLR ACTED              | RESET            | 01:40:00 | 01:50:00 |         |
| 3     | OHP  | TIS 2                    | BELT MOTOR MPCB TRIP   | MADE IT ON       | 00:25:00 | 00:30:00 |         |
| 4     | OHP  | CO 12                    | OLR ACTED              | RESET            | 00:40:00 | 00:45:00 |         |
| 5     | CHP  | CC 125                   | OLR ACTED              | RESET            | 03:15:00 | 03:20:00 |         |
| 6     | CHP  | CC 51A                   | OLR ACTED              | RESET            | 02:10:00 | 02:15:00 |         |
| 7     | CHP  | CC 51                    | FEEDING CONV OLR ACTED | RESET            | 04:35:00 | 05:20:00 | 2 TIMES |
| 8     | CHP  | CC 52                    | FEEDING CONV OLR ACTED | RESET            | 04:40:00 | 06:00:00 | 3 TIMES |