



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 03/09/2026

Incharge(s): G Eswara Rao

Shift: B

| Sl No | Area | Equipment     | Problem                                                   | Action                       | From     | To       | Remarks                 |
|-------|------|---------------|-----------------------------------------------------------|------------------------------|----------|----------|-------------------------|
| 1     | OHP  | BRC ON CO 8A  | NO DRIVES RUNNING/ACB TRIPPED                             | ACB MADE ON THEN OK          | 16:40:00 | 17:00:00 |                         |
| 2     | OHP  | VF 21         | MPCB KEPT OFF DUE TO JAMMING                              | AFTER CLEARENCE MPCB MADE ON | 17:30:00 | 18:00:00 |                         |
| 3     | CHP  | CC 131        | TRIPPED ON OLR                                            | RESET DONE                   | 18:15:00 | 18:25:00 |                         |
| 4     | CHP  | CC 132        | PC ACTED/                                                 | RESET DONE                   | 14:40:00 | 14:50:00 |                         |
| 5     | CHP  | SCR 2 ON CC33 | LT NOT TAKING PLACE PCRD ZSS ACTED                        | RESET DONE                   | 19:50:00 | 20:05:00 |                         |
| 6     | WT   | OP 2          | F/R NOT TAKING PLACE/M3 OLR ACTED                         | RESET DONE                   | 18:15:00 | 18:30:00 |                         |
| 7     | WT   | CO 4 C/D      | TRIPPED ON OLR                                            | RESET DONE                   | 14:40:00 | 14:50:00 |                         |
| 8     | WT   | OT 4          | HYDROLIC PUMP 1 NOT RUNNING/Y PHASE GOT BURNT IN MOTOR TB | SELECTION CHANGED TO PUMP 2  | 18:50:00 | 19:00:00 | FOR AVOID TIPLING DELAY |