



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/06/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 28	B/C OLR ACTED	RESET	16:10:00	16:25:00	
2	OHP	BRC ON CO 28	B/W 1 OLR ACTED	RESET	18:40:00	18:50:00	
3	OHP	WBR ON CO 29	LUFF OLR ACTED	RESET	18:40:00	18:50:00	
4	OHP	CO 85	OLR ACTED	RESET	19:20:00	19:30:00	
5	OHP	CO 26	OLR ACTED	RESET	21:25:00	21:30:00	
6	OHP	CO 48	OLR ACTED	RESET	19:00:00	19:05:00	
7	CHP	S2 ON CC 39 LT	M1 OLR ACTED	RESET	15:35:00	15:45:00	
8	CHP	SCR 2 ON CC 33	LT PCRD DRUM SENSOR ACTED	RESET	20:00:00	20:15:00	