



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 28/04/2026

Area: OHP

Equipment	Job
wobr-1 on co-29	shifted from co-29 to co-26
wobr-3 on co-26	shifted from co-26 to repair bay
vf-19	both motors were removed for mechanical tray job, fixed back after the job completion
brc-4 on co-8a	chp side spare thruster brake is installed and tested, kept in circuit.