



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/04/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 25	LT not working,brake not working,fuse problem	new fuse wire inserted	15:30:00	15:50:00	
2	OHP	co 25	olr acted	reset	18:25:00	18:35:00	
3	OHP	CO 3A	zss acted ,cage got broken	cage replaced	15:30:00	16:10:00	
4	CHP	CO 35	olr atced	reset	20:10:00	20:15:00	
5	CHP	CC 39 SCR7	LT not working,drive tripped	reset	18:20:00	18:30:00	
6	CHP	CC 31 SCR1	b/c not running,all ok	fault reset done than ok	17:20:00	17:30:00	3 times
7	CHP	CC 216	mpd acted	reset	20:45:00	20:55:00	
8	WT	OP5	no movement,d3 olr acted	reset	16:35:00	16:55:00	