



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/08/2026

Incharge(s): Nagendra Midde,K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	OLR ACTED (2TIMES)	RESET DONE	17:45:00 18:45:00	17:55:00 18:50:00	
2	OHP	BRC ON CO-28	B/C OLR ACTED	RESET DONE	16:40:00	16:50:00	
3	CHP	CC-115	REPORTED STOPPING ON ZSS FOUND ZSS CAGE STUCK UP	RELEASED THAN OK	18:45:00	19:00:00	
4	IOSA	LT WOBR	LT NOT TAKING PLACE FOUND PCRD O/T ACTED	RELEASED	19:55:00	20:15:00	