



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/09/2026

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	OLR ACTED (4TIMES)	RESET DONE	09:10:00	11:25:00	
2	OHP	CO-33M	OLR ACTED	RESET DONE	09:30:00	09:35:00	
3	OHP	WOBR ON CO-29	REPORTED LT NOT TAKING PLACE FOUND M-1 OLR ACTED	RESET DONE	09:35:00	09:45:00	
4	OHP	WOBR ON CO-25	PCRD O/T ACTED FREQUENTLY FOUND LIMIT PROBLEM	LIMIT ADJUSTED THAN OK	06:30:00	07:00:00	NO ELECTRICAL DELAY