



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/09/2026

Incharge(s): Nagendra Midde,Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR ACTED	RESET	22:35:00	22:50:00	
2	OHP	CO 26	OLR ACTED	RESET	05:25:00	05:35:00	
3	OHP	WBR ON CO 25	PCRD CAM LIMIT SWITCH PROBLEM	BYPASSED	02:20:00	02:50:00	
4	CHP	CC 58	OLR ACTED	RESET	01:45:00	02:00:00	
5	CHP	CC 18	P/C NOT RESETTING	BYPASSED	02:00:00	02:30:00	
6	WT	OP2	D1 TRIPPED	RESET	02:00:00	02:10:00	