वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 17/10/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR on CO 29 b/w	Stone stuck up	Informed to oprn	00:15:00	00:35:00	
2	OHP	RCO 6a	OLR acted	Reset	01:00:00	01:15:00	
3	OHP	VF 10 a	OLR acted	Reset	02:15:00	03:30:00	2 times
4	CHP	CC 131	OLR acted	Reset	02:05:00	02:10:00	
5	CHP	CC 125	OLR acted	Reset	05:10:00	05:15:00	
6	CHP	SCR on CC 105 Slew	limit acted due to Jamming	Informed to oprn	01:00:00	01:15:00	
7	CHP	SCR 6 ON CC 38 B/C	C/S acted	Bypassed	05:15:00	05:30:00	