



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/06/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 8A	b/w 1 not running,ZSS acted	bypass in i/o rack	01:30:00	01:45:00	
2	OHP	co 25	olr acted	reset	23:10:00	23:20:00	
3	OHP	tbs on co 21	Rbc not running,olr acted,cs acted due to jamming	informed operation	22:30:00	22:45:00	
4	OHP	wobr on co 29	b/w not running,smoke coming from motor	wrong complain,smoke coming from gear box,informed mechanical	02:30:00	02:45:00	
5	CHP	CC 131	olr acted 6 times	reset	23:50:00	23:55:00	
6	CHP	CC 51	mpd acted	reset	03:15:00	03:20:00	
7	CHP	CC 52	mpd acted	reset	03:20:00	03:25:00	
8	CHP	CC 31 scr1	slew right not working,limit acted due to jamming	informed operation	22:35:00	22:45:00	
9	CHP	cc 38 scr5	b/c not running in reclaiming mode,CS acted	sensor cleaned than ok	01:55:00	02:05:00	
10	CHP	CC 106 SCR6	B/C not running CS acted due to rain	bypassed in module	02:45:00	03:00:00	