



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/06/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO 7A	LBC LUFFING NOT TAKING PLACE/	BRAKE DRUM STUCKUP WITH BRAKE SHOES/MECHANICAL ADJUSTMENT DONE THEN OK	07:10:00	08:00:00	NO DELAY
2	OHP	WOBR ON CO 6A	NO DRIVES RUNNING/ACB TRIPPED	ACB MADE ON THEN OK	08:15:00	08:30:00	
3	OHP	BRC ON CO 8A	NO DRIVES RUNNING/ACB TRIPPED	ACB MADE ON	08:30:00	08:40:00	
4	OHP	BRC ON CO 8A	BC NOT RUNNING/YARD INTERLOCK ZSS CAGE STUCKUP	ZSS CAGE REPLACED	08:30:00	09:00:00	
5	OHP	WOBR ON CO 25	BC NOT RUNNING/ZSS CAGE STUCKUP	CAGE MADE FREE	09:50:00	10:10:00	
6	OHP	CO 29	TRIPPED ON OLR	RESET DONE	12:25:00	12:30:00	
7	OHP	CO 35A	BRS ACTED/SENSOR GOT BOKEN	BYPASSED AT I/O RACK	12:45:00	12:55:00	NOT RUNNING COMPLAINT
8	CHP	CC 28	TRIPPED ON OLR	RESET DONE	12:35:00	12:45:00	
9	CHP	SCRV 5 ON CC38	BC NOT RUNNING/30 DEGREE LIMIT ACTED	BYPASSED AT I/O PANEL	06:50:00	07:05:00	
10	WT	AF 3	TRIPPED ON OLR	DRIVE RESET DONE	11:40:00	11:50:00	