# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 05/11/2026

Area: OHP

| Equipment | Job |
|---|---|
| brc-3 on co-34 | shifted from co-34 to co-33m |
| brc-4 on co-8a | ct festoon cables loop adjusted. Logic modified such that Charge pressure ,accumulator pressure faults will now withdraw bucket wheel command, instead of stopping pump. |
| wobr-2 on co-29 | pcrd cable wounded onto drum and shifted to repair bay. lighting and welding machine supply provided for repair bay jobs |