



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/09/2026

Incharge(s): Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-58	TRIPPED MPCB	RESET DONE	11:00:00	11:10:00	
2	OHP	VF-10	MPCB TRIPPED	BASE PLATE DAMAGED AND FALLEN ... INFORMED MECH	12:20:00	12:30:00	
3	OHP	BRC ON CO -30	BC COUPLING PROBLEM	INFORMED MECH	08:00:00	08:20:00	
4	OHP	BRC ON CO -30	BC NOT RUNNING	MCCB IN OFF ... MADE ON	11:00:00	11:15:00	
5	OHP	VS-1A	TRIPPED ON OLR	RESET	10:30:00 11:10:00	10:40:00 11:20:00	
6	OHP	BRC ON CO-8A	AIR BLAST COOLER TRIPPING	G SHIFT ON THE JOB	10:00:00	10:30:00	
7	CHP	CC-131	TRIPPED ON OLR	RESET DONE	08:35:00 09:45:00	08:40:00 09:50:00	
8	IOSA	FLS WBR	PCRD OVER TENSION ACTED	RELEASED	07:25:00	07:35:00	