



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/06/2026

Area: OHP

Equipment	Job
wobr-2 on co-25	slip ring, transformer , ppm is done. BW motor trail run is taken.
co-30,31,32	mechanical brs installation is under progress.
co-19, wobr-3 on co-25 bc and bw motors ; co-6a	vibration readings were taken.
co-1a	pcs, zss, brs inspection is done.
JH O-2 tunnel	tunnel lighting is improved, new fixtures installed, circuit rectification is being done.
37kw 225s, LHP motor	shifted to rco-1a h/e as its spare.
co-60,63,66,69	safety devices ppm is done.
EOT-2 remote panel	installation , cable laying is under progress.