



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/06/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	13:20:00	13:25:00	
2	CHP	SCR 4 ON CC 32 LT	M9 TRIPPED	RESET	06:55:00	07:05:00	
3	CHP	SCR 7 ON CC 39	LT END LIMIT	PROPERLY FIXED THEN OK	08:20:00	08:40:00	