



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 04/06/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

| Sl No | Area | Equipment      | Problem                       | Action             | From     | To       | Remarks |
|-------|------|----------------|-------------------------------|--------------------|----------|----------|---------|
| 1     | OHP  | CO 26          | olr acted                     | reset              | 19:00:00 | 19:10:00 |         |
| 2     | CHP  | cc 51          | mpd acted                     | olr acted          | 20:50:00 | 20:55:00 |         |
| 3     | CHP  | CC 47          | EStop acted                   | released           | 15:45:00 | 15:55:00 |         |
| 4     | CHP  | CC 44          | mpd tripped                   | reset              | 16:40:00 | 16:45:00 |         |
| 5     | CHP  | CC 104<br>SCR6 | LT not working, track jamming | informed operation | 16:50:00 | 17:00:00 |         |
| 6     | CHP  | CC 125         | mpd tripped                   | reset              | 20:20:00 | 20:25:00 |         |
| 7     | WT   | CO 4(B)        | Emergency PB stucked          | released properly  | 19:30:00 | 19:45:00 |         |