



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/08/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	olr acted	reset	16:20:00	16:30:00	
2	OHP	WOBR on co 29	LT not working,OT acted,pcrd gear box problem	loop given ,informed mechanical and operation	20:00:00	20:15:00	
3	CHP	cc 28	flap gate motor mpcb tripped	made it on	17:30:00	17:40:00	
4	CHP	CC 37 scr3	luff not working,pump off high cable came out of TB	connected properly	14:35:00	14:50:00	
5	CHP	cc 37 scr3	no communication,modem mcb tripped	made it on	16:00:00	16:20:00	