



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/08/2026

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO-25	LT M4 TRIPPED	RESET DONE	01:10:00	01:25:00	
2	OHP	CO-26	TRIPPED ON OLR	RESET DONE	01:30:00	01:40:00	
3	OHP	WBR ON CO-26	LT AND SLEW NOT WORKING	LT M4 RESET ... SLEW DRIVE RESET	03:40:00	03:55:00	
4	OHP	CO-25	OLR ACTED	RESET DONE	04:25:00	04:30:00	
5	CHP	CC-52	TRIPPED 2 TIMES	RESET DONE	01:50:00	02:40:00	
6	CHP	CC-54	MOTOR TRIPPED ON OLR	RESET DONE	05:00:00	05:10:00	
7	IOSA	WOBR L and T	LT NOT WORKING	PROGRAM CHANGED ... WIRING ALSO CHANGED ACCORDINGLY ..TESTED	22:00:00	01:30:00	
8	IOSA	BRC	CT DRIVE TRIPPED ON OVER CURRENT	RESET DONE	04:45:00	05:05:00	
9	IOSA	OC-14A	MASTER TRIP RELAY ACTED	RESET DONE AND TESTED	23:15:00	23:30:00	