



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/06/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-32	REPORTED B/W S NOT RUNNING FOUND OIL LEVEL FAULT	INFORMED TO MECHANICAL	07:45:00	07:55:00	
2	CHP	BRC ON CO-32	REPORTED LT OT TAKING PLACE FOUND DRIVE-2 TRIP	RESET DONE	10:30:00	10:40:00	
3	CHP	CC-37 SCR-3	REPORTED SLEW NOT WORKING SLEW LIMIT ACTED (DUE TO COAL PIC JAMMING	LIMIT RELEASE AFTER CLEAR JAMMING THAN OK	08:45:00	08:55:00	
4	WT	OT-1	BRAKE CONTACTOR NOT PICK UP PROPERLY	ALL CONNECTIONS TIGHT THAN OK	13:10:00	13:40:00	