



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/10/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO 19	LT drive tripping	M1 disconnected Then ok	12:30:00	13:15:00	To be checked
2	OHP	BRC on CO 28	BW1 Motor Changed	Given Clearance	06:00:00	10:30:00	
3	OHP	VS2 C/S	Malfunctioning	Bypassed	12:45:00	13:15:00	Informed to Instrumentation