



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 10/06/2026

Area: OHP

Equipment	Job
wobr-4 on co-6a	hydraulic oil tan temperature trip was changed from 65 to 70 and reset from 60 to 65 on mechanical request.