



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 09/06/2026

Shift: A

Incharge(s): G Eswara Rao

| Sl No | Area | Equipment      | Problem                                        | Action                                                                 | From     | To       | Remarks                   |
|-------|------|----------------|------------------------------------------------|------------------------------------------------------------------------|----------|----------|---------------------------|
| 1     | OHP  | TBS ON CO 7A   | LBC LUFFING NOT TAKING PLACE/                  | BRAKE DRUM STUCKUP WITH BRAKE SHOES/MECHANICAL ADJUSTMENT DONE THEN OK | 07:10:00 | 08:00:00 | NO DELAY                  |
| 2     | OHP  | WOBR ON CO 6A  | NO DRIVES RUNNING/ACB TRIPPED                  | ACB MADE ON THEN OK                                                    | 08:15:00 | 08:30:00 |                           |
| 3     | OHP  | BRC ON CO 8A   | NO DRIVES RUNNING/ACB TRIPPED                  | ACB MADE ON                                                            | 08:30:00 | 08:40:00 |                           |
| 4     | OHP  | BRC ON CO 8A   | BC NOT RUNNING/YARD INTERLOCK ZSS CAGE STUCKUP | ZSS CAGE REPLACED                                                      | 08:30:00 | 09:00:00 |                           |
| 5     | OHP  | WOBR ON CO 25  | BC NOT RUNNING/ZSS CAGE STUCKUP                | CAGE MADE FREE                                                         | 09:50:00 | 10:10:00 |                           |
| 6     | OHP  | CO 29          | TRIPPED ON OLR                                 | RESET DONE                                                             | 12:25:00 | 12:30:00 |                           |
| 7     | OHP  | CO 35A         | BRS ACTED/SENSOR GOT BOKEN                     | BYPASSED AT I/O RACK                                                   | 12:45:00 | 12:55:00 | NOT RUNNING<br>COMPLAIN T |
| 8     | CHP  | CC 28          | TRIPPED ON OLR                                 | RESET DONE                                                             | 12:35:00 | 12:45:00 |                           |
| 9     | CHP  | SCRV 5 ON CC38 | BC NOT RUNNING/30 DEGREE LIMIT ACTED           | BYPASSED AT I/O PANEL                                                  | 06:50:00 | 07:05:00 |                           |
| 10    | WT   | AF 3           | TRIPPED ON OLR                                 | DRIVE RESET DONE                                                       | 11:40:00 | 11:50:00 |                           |