



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/06/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WB ON CO 29	LUFF OLR ACTED	RESET	22:30:00	22:40:00	
2	OHP	CO 26	OLR ACTED	RESET	23:25:00	23:35:00	
3	OHP	TT3 ON CO 21	POSITION CABLE GOT CUT	REJOINED THEN OK	22:30:00	22:40:00	
4	CHP	SCR 4 ON CC 32 LT	DRIVE TRIPPED	RESET	23:05:00	23:15:00	
5	CHP	SCR 2 ON CC 33	B/W DRIVE TRIP	RESET	01:25:00	01:35:00	
6	CHP	SCR 5 ON CC 35	SLEW 30 DEGREE LIMIT ACTED	RELEASED	01:30:00	01:40:00	
7	CHP	SCR 3 ON CC 37 COMMUNICATION	MODEM POWER TRIPPED	MADE IT ON	02:45:00	03:30:00	
8	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	23:20:00	00:40:00	2 TIMES
9	CHP	CC 131	OLR ACTED	RESET	01:15:00	01:25:00	