



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/06/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 61 BRS	CJB TO MODULE CORE PROBLEM	CORE REPLACED THEN OK	17:00:00	17:25:00	
2	OHP	WBR ON CO 25	LUFF OLR ACTED	RESET	14:50:00	15:05:00	
3	OHP	CO 29	PC EARTH FAULT	BYPASSED	17:05:00	17:20:00	
4	OHP	WBR ON CO 6A	ZSS INTERLOCK CAGE IS LIFTED AND TIED	PROPERLY PLACED	18:30:00	18:50:00	
5	OHP	RSCO 10 A	OLR ACTED	RESET	21:15:00	21:25:00	