वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 06/11/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 48	OLR acted	Reset	03:35:00	03:55:00	
2	OHP	CO 56	OLR acted	Reset	04:10:00	04:25:00	