



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/07/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 30 LT	PCRD DRUM TO GEAR BOX CHAIN SLIP O/T ACTED	INFORMED TO MECH	02:20:00	02:35:00	
2	OHP	WBR ON CO 29 LT	DRIVE TRIP	RESET	02:20:00	02:40:00	
3	OHP	BRC ON CO 8A	ACB BREAKER IN OFF CONDITION	MADE IT ON	02:30:00	02:55:00	
4	OHP	CO 26	OLR ACTED	RESET	02:45:00	03:00:00	
5	OHP	CO 29	OLR ACTED	RESET	03:30:00	03:50:00	
6	OHP	BRC ON CO 28 B/C	OLR ACTED	RESET	03:50:00	04:10:00	