



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 11/08/2026

Incharge(s): K SANKARA RAO

Shift: C

| Sl No | Area | Equipment      | Problem                                                                         | Action                | From                 | To                   | Remarks |
|-------|------|----------------|---------------------------------------------------------------------------------|-----------------------|----------------------|----------------------|---------|
| 1     | OHP  | brc on co-32   | REPORTED YARD INTERLOCK ZSS CAGE NOT ROTATED FOUND ZSS CAGE STUCK UP WITH STONE | STONE REMOVED THAN OK | 00:00:00             | 00:20:00             |         |
| 2     | OHP  | CO-25          | OLR ACTED                                                                       | RESET DONE            | 00:35:00             | 00:45:00             |         |
| 3     | OHP  | CO-29          | OLR ACTED                                                                       | RESET DONE            | 04:30:00             | 04:35:00             |         |
| 4     | OHP  | CO-26          | OLR ACTED                                                                       | RESET DONE            | 04:30:00             | 04:35:00             |         |
| 5     | CHP  | CC-54          | MPD TRIP                                                                        | RESET DONE            | 05:20:00             | 05:25:00             |         |
| 6     | CHP  | CC-131         | OLR ACTED ( 2TIMES)                                                             | RESET DONE            | 01:35:00<br>05:20:00 | 01:45:00<br>05:30:00 |         |
| 7     | CHP  | CC-40<br>SCR-7 | B/C OLR ACTED                                                                   | RESET DONE            | 05:20:00             | 05:30:00             |         |