



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/08/2026

Incharge(s): Nagendra Midde

Shift: B

| Sl No | Area | Equipment       | Problem                          | Action            | From     | To       | Remarks |
|-------|------|-----------------|----------------------------------|-------------------|----------|----------|---------|
| 1     | OHP  | CR 1            | OLR acted                        | Reset             | 17:20:00 | 17:30:00 |         |
| 2     | OHP  | Rsc0 2a         | CD MPCB trip                     | Made it on        | 18:00:00 | 18:10:00 |         |
| 3     | OHP  | CO 25           | OLR acted                        | Reset             | 18:10:00 | 18:20:00 |         |
| 4     | OHP  | WBR on CO 6A LT | Selector switch is in LOCAL mode | Changed to Remote | 18:05:00 | 18:15:00 |         |
| 5     | CHP  | SCR 5 on CC 32  | PCRD cable Fell down             | Winding done      | 16:20:00 | 16:40:00 |         |
| 6     | CHP  | CC 35           | ZSS Probe Damaged                | Replaced          | 17:15:00 | 17:45:00 |         |
| 7     | CHP  | SCR 2 on CC 33  | B/W drive trip                   | Reset             | 18:30:00 | 18:45:00 |         |
| 8     | CHP  | CC 21 CD        | MPCB trip                        | Reset             | 17:00:00 | 17:10:00 |         |