



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/07/2026

Area: WT

Equipment	Job
DE 2	Fan Motor testing done in no load
OP 7,8 and CP 1	# Phase Indicator Lamps installation and connection done on pushers
LC 10A	Area lighting ,350W LEDs installation and connection done at four corners
OT 1	Cabin area one 200W LED and 2 nos Tubes installed
MIS	Preparatory job done for OT 5 track indication device