



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 17/07/2026

Incharge(s): G Eswara Rao

Shift: B

| Sl No | Area | Equipment     | Problem                                                       | Action                              | From                 | To                   | Remarks                     |
|-------|------|---------------|---------------------------------------------------------------|-------------------------------------|----------------------|----------------------|-----------------------------|
| 1     | OHP  | WOBR ON CO 25 | LT NOT TAKING PLACE/PCRD TENSION ACTED                        | PCRD TENSION RELEASED 2 TIMES       | 14:45:00<br>15:25:00 | 15:00:00<br>15:30:00 | MOTOR TO DRUM CHAIN PROBLEM |
| 2     | OHP  | VF 19         | MPCB TRIPPED                                                  | MADE ON                             | 15:20:00             | 15:30:00             |                             |
| 3     | OHP  | TBS ON CO 20  | LT NOT TAKING PLACE/PCRD TENSION ACTED DUE TO CABLE ENTANGLED | CABLE WINDING DONE ALONG WITH MECH. | 18:30:00             | 20:10:00             |                             |
| 4     | OHP  | WOBR ON CO 6A | SLEW ING NOT TAKING PLACE/OIL LEVEL LOW                       | INFORMED TO OPERATION               | 21:10:00             | 21:20:00             |                             |
| 5     | CHP  | SCR 3 ON CC37 | BC NOT RUNNING/MPD TRIPPED ON OLR                             | RESET DONE                          | 16:05:00             | 16:15:00             |                             |
| 6     | CHP  | CC 107        | TRIPPED ON OLR                                                | RESET DONE                          | 19:15:00             | 19:20:00             |                             |
| 7     | CHP  | CC 131        | MPD TRIPPED ON OLR                                            | RESET DONE                          | 17:25:00             | 17:30:00             |                             |
| 8     | CHP  | CC58          | TRIPPED ON OLR                                                | RESET DONE                          | 21:50:00             | 22:00:00             |                             |