



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/09/2026

Shift: A

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment     | Problem                       | Action                                                                                    | From     | To       | Remarks                         |
|-------|------|---------------|-------------------------------|-------------------------------------------------------------------------------------------|----------|----------|---------------------------------|
| 1     | OHP  | wobr on co 6A | LT not working,s/s in local   | kept in remote                                                                            | 06:25:00 | 06:40:00 |                                 |
| 2     | OHP  | wobr on co 6A | b/c not running,mccb tripped, | megger done found 0.1 mohm,hot blowing done ,contactor insulation provided,v1 and w1 lead | 09:00:00 | 12:30:00 | trial run taken given clearance |
| 3     | OHP  | co 26         | olr acted                     | reset                                                                                     | 10:05:00 | 10:15:00 |                                 |
| 4     | OHP  | co 21         | zss acted,probe wire got cut  | wire connected                                                                            | 11:45:00 | 12:10:00 |                                 |
| 5     | OHP  | tbs on co24   | LT not working,s/s in local   | kept in remote                                                                            | 12:35:00 | 12:50:00 |                                 |
| 6     | OHP  | TBS on CO 21  | LT not working,m3 olr acted   | reset                                                                                     | 13:00:00 | 13:20:00 |                                 |
| 7     | IOSA | brc           | b/w 2 not running,zss acted   | sensitivity adjusted                                                                      | 09:20:00 | 09:40:00 |                                 |