



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/08/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav,P Venkat Kiran,P Venkat Kiran

| Sl No | Area | Equipment       | Problem                                             | Action                             | From                 | To                   | Remarks |
|-------|------|-----------------|-----------------------------------------------------|------------------------------------|----------------------|----------------------|---------|
| 1     | OHP  | co-25           | olr tripped                                         | reset done                         | 16:45:00<br>21:50:00 | 16:55:00<br>22:00:00 |         |
| 2     | OHP  | wobr-3 on co-25 | It no taking place, m4 tripped due to track jamming | informed operation and reset done. | 17:35:00             | 17:50:00             |         |
| 3     | CHP  | CC 52           | mpd tripped                                         | reset                              | 14:30:00             | 14:35:00             | 3 times |