# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 23/10/2026

Area: CHP

| Equipment | Job |
|---|---|
| SCR 7,8,9,10.R 1 | Machine inspection done for safety switches and HT coupler heaters |
| SCR 2,3,4,5 | Instrumentation sensors maintenance was done |
| CC 42,111,SCR 4 | PPM was done |
| RG 1,VS 1,VF 1 | PPM was done |
| I/C 5 ( CC 38) | Bus bar maintenance done |
| CM 17 | Bus bar maintenance was done |
| CM 6 | Original ACB placed and charged |
| CC 9 | Panel out going B phase damaged Cu bus and lugs replaced ,terminate and trail run was taken |